



KEYNOTES

- ① SUB-BASE OPTIONS PER ADA GUIDELINES: (1) COMPACTED AGGREGATE - 4" OF 3/4" MINUS IRREGULAR STONE WITH FINES COMPACTED TO 95% IN 2" WATERED LIFTS. (2) CONCRETE - MINIMUM OF 3-4" AT A MINIMUM 2500 PSI. MUST CURE FOR 7 DAYS PRIOR TO CUSHION LAYER. MUST CURE FOR 28 DAYS IF WEAR COURSE IS TO BE APPLIED DIRECTLY TO CONCRETE SURFACE. (3) ASPHALT - MUST CURE A MINIMUM OF 14 DAYS, POWER WASHED
- ② NAIL BOARD TO BE INSTALLED 3/8" BELOW FINISHED GRADE; NAIL OR STAPLE TO SECURE TURF AT NAIL BOARD
- ③ CONCRETE CURB, WALL, OR BORDER AREA
- ④ SBR CUSHION LAYER OR FOAM PAD PER JOB SPECIFICATIONS (DEPTH VARIES BY CRITICAL FALL HEIGHT)
- ⑤ SYNTHETIC TURF, INSTALL PER MANUFACTURER GUIDELINES
- ⑥ 1.5 - 2.5 LBS/SF INFILL PER MANUFACTURER GUIDELINE TO GRADE LEVEL
- ⑦ TURF NAIL BOARD SECURED TO CONCRETE OR BORDER AREA. (2" X 4" COMPOSITE WOOD IS PREFERRED, PRESSURE TREATED LUMBER IS ACCEPTABLE)

ROBERTSON RECREATIONAL SERVICES
ADDRESS: 2414 W. 12TH STREET SUITE 5
TEMPE, ARIZONA 85281
PHONE: 800-858-0619
WEBSITE: WWW.TOTURF.COM

DETAIL-13
SYNTHETIC TURF (NAIL BOARD)

DATE: 09-13-2016
REVISION DATE: 12-12-2016
SCALE: N.T.S.
DRAWN BY: ATL
SIGNED/APPROVED: